

19078

TAP CLEARED

27-29

Felton W.S., S. of Hersom

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

Wm. Forrest

9/6/57

reamed

5/8"

S. from

Hersom

84.3

E from<sup>W</sup> line

Felton

10.0

S f r o m N l i n e

House

10.5

Sept. 6, 1957 Repaired leak at tap  
1 lb. wiping solder

Oct. 30, 1957 Renewed from curb stop to a point 3 ft. inside curb stop  
3 ft. of 3/4" copper tubing

Dec. 22, 1961 Renewed from main to curb stop

10 $\frac{1}{2}$  ft. of 3/4" copper tubing      3/4" cop. to cop. stop, fig. 415RH  
5/8" Reused corp. cplg.      lb. wiping solder

3/3/05 Renewed from 3 ft inside curb stop to ins cellar (14 ft ins  
prop. line) STOCK: 20 ft 3/4" copper tubing; 1 - 3/4 x 3/4  
cop to cop cplg., comp

[illegible]

# CHARGE OUTS