

APPLICATION No.: 19089

TAP CLEARED 8716-1221 ✓

LOCATION: S.W. Cor. 207 Mt. Pleasant & Coggeshall

OWNER: George Viegant

MEASURES: 3/4"

W from	Mt. Pleasant	49.3 ft.
N from S line	Coggeshall	8.2 ft.
E from W line	House	9.2 ft.

4/14/87: Renewed from 1/2' outside curb stop to ins. cellar.
 (20 ft. ins. prop line) Stock: 29ft. 3/4" copper tubing
 1 - 3/4" curb stop 1-Caldwell stop box 1-3/4x 5/8 lead to cop
 adapt. xxs.

2/3/94: Renewed from main to a point 3ft in front of main
 Stock: 3ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs
 1-3/4x3/4 Fig 413

10-25-01 Renewed from main to curb stop. Stock: 10ft.-3/4" Copper
 tubing, 1-3/4" Curb Stop.

4/29/04 Repaired 6" sanitary drain; appears to have been broken
 by DPI Stock: 3 ft. 6" PVC; 1 - 6" straight fernco; 1 - 6" clay-
 PVC fernco

DATE

BEF.

AFT.

REMARKS

2/3/94: tap reamed

10/22/01

9:45
am

2001 4205861

10-25-01 Tap reamed

[illegible]

CHARGE OUTS

[illegible]