

SERVICE✓

Application No. 19126

St. & No. N.W. Cor. Purchase and Maxfield

Size Pipe Kind Pipe Laid

6" C.I. Nov. 28, 1922.
Darling gate, I. box

W from W Purchase 90.6 St. - 91.1 ft.

S from N line Maxfield 50.3 St. - 7.0 ft.

~~E from W line - 8 ft. - 21.0 ft.~~

Measures of 8 x 8 x 6" tee (over)

24 ft. C.I. pipe including specials.

City

ft. Earth

Taker

ft. Earth.

ft. Pipe

ft. Pipe

Total bill 160 71

P. 59/66

REMOVED 7-12-2005

Measure of 6" Dresser #138 Sleeve:

W x W line Purchase 92.0

S x N line Maxfield 28.6

Jan. 1975 Installed 8" x 8" x 6" tee (mech.)
for Fire Supply 1.4 ft. piece of 6" C.I. SS
8" x 8" x 6" Tee, Mechanical
18 ft.-6" C.I. pipe
6" Dresser Style 138 sleeve

7-12-2005 - REMOVED / SHUT OFF @ GATE
CAPPED IN SIDE WALK STOCK 1-C#441 CAST
CPLG. W/PLATE AS A CAP.