

APPLICATION No.: 1914

TAP CLEARED

LOCATION: 223 Acushnet Ave.

OWNER: Helen I. Monteiro

DATE

BEF.

AFT.

REMARKS

1/5/65

Reamed

MEASURES: 3/4" Copper Sept. 23, 1874

N from Russell St. 112.4 ft.

E from W line Ave. 6.5 ft.

N from S line house 5.2 ft.

Renewed from main to 6" inside curb stop. Jan. 5, 65  
7½ ft. - 3/4" Copper 3/4" cop to cop stop  
3/4" copper cplg. 5/8" reused corp. cplg.

Renewed from curb stop to property line. Oct. 8, 62  
7 ft. - 3/4" Copper 1 lb. wiping solder

NOTE: Owner's plumber Spach installed 13 ft. of 3/4"  
copper tubing from property line to meter inside bldg.

7/31/80: leak at coupling on corp. tap. Inst. new washer  
and cleared corp. tap.

## METER HISTORY

[illegible]

## CHARGE OUTS