

APPLICATION No.: 19141

TAP CLEARED

LOCATION: 145 Nye N.S. E. of Brook

OWNER: Arsene Ricard

MEASURES:	5/8"		
	E from	Brook	115.3 ft.
	S from N line	Nye	9.0 ft.
	E from E line	Bldg.	29.0 ft.

October 6, 1959 Wiped one joint on outlet side of meter inside meterbox in sidewalk.

1 lb. wiping solder

September 19, 1961 Renewed from curb stop to meter inside building.

47 ft. of 3/4" copper tubing type K, soft
(owner supplied and installed 38 ft. from property line to inside
building - meter was relocated from meter box in sidewalk to
cellar. Wooden meter box filled in - frame and cover returned
to repair shop.)

1 lb. wiping solder

8-4-83 Renewed from tap to 1' from main.

1-3/4" x 5/8" Fig. 413 1'-3/4" copper

1-3/4" x 5/8" lead-cop. adapt. XS

2/4/08 - Renewed service from main to property line
22 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell
stop box; 1 - 5/8" x 3/4" Fig. 413; Tap reamed.

Foreman: Dennis Monty

DATE _____

BEF.

AFT.

REMARKS

18/08	8:00
-------	------

DIG Safe #

2008-0303415

2-4-08

Tap reamed

[illegible]

CHARGE OUTS

[illegible]