

256-58 Mt. Pleasant St.

APPLICATION No.: 19166

TAP CLEARED 9/24-3626

LOCATION: 256-58 Cor. Mt. Pleasant & Sawyer

OWNER: B. Dussault

MEASURES: 3/4"

E from

Mt. Pleasant

45.0 ft.

N from S line

Sawyer

8.0 ft.

W from E line

House

19.3 ft.

May 1, 1975 Renewed from the curb stop to inside cellar.
1 - 3/4" Curb stop 12 ft. - 3/4" Copper
Caldwell Stop Box tubing
5/8" x 3/4" lead to cop. adapt. XXS
- - -

Oct. 16, 1980: Renewed from main to 1 ft. front of main.
1.0 ft. - 3/4" copper
1-3/4" x 3/4" Fig. 413 Tap reamed
1-5/8" x 3/4" lead-cop. adapt. XXS
- - - -

6/13/91: TAP REAMED

10/13/93: Ch.90 Project

Medeiros Const. renewed service from main to curb stop

Cont supplied & installed all stock:

8ft 3/4" copper tubing same 3/4" curb stop same Caldwell
stop box 1-3/4x3/4 Fig 413 Insp M Rose III
=====

**** Turn over for more repairs ****

DATE

BEF.

AFT.

REMARKS

OCT 16 1980

Reamed

6/13/91: TAP REAMED

10/13/93: tap reamed

[illegible]

copper tubing;