

APPLICATION No.: **19193**

TAP CLEARED

LOCATION: **98-100 Willard S.S., E. of W. French Ave.**OWNER: **Micheal Lajae**MEASURES: **5/8"**

E from	W. French Ave.	140.1 ft.
N from S	Willard	7.5 ft.
E from W	house	9.9 ft.

7-18-01 Renewed from main to property line. Stock: 18 ft. - 3/4"
property line. 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box,
1 - 5/8" x 3/4" lead to cop. adapt. XXS, 1 - 5/8" x 3/4" Fig. 413.

↓
W X E Jouse 16.0'
N x N House 17.0'

Main to property line 18.0'
Pipe inside property 17.0'

12/20/17: Service renewed from curb stop to meter, Contractor: JLC Construction
Inspector P. Reynolds

DATE

BEF.

AFT.

REMARKS

Tap reamed 7-18-01

[illegible]

CHARGE OUTS