

APPLICATION No.: 19194

TAP CLEARED ✓

LOCATION: 287 Shaw N.S. E. of Ashley Blvd.OWNER: Edw. MeyerMEASURES: 5/8"

E from	Ashley Blvd.	217.0 ft.
S from N line	Shaw	9.1 ft.
W from E line	House	9.8 ft.

12/5/77: Renewed 6" outside curbstop to property line.  $7\frac{1}{2}$  ft. -  $3\frac{1}{4}$ "  
copper;  $3\frac{1}{4}$ " curb stop; 2- $5\frac{1}{8}$ " x  $3\frac{1}{4}$ " lead to cop. adapt. XS;  
Caldwell stop box;

2/9/95:

Renewed from curb stop to ins.cellar (16ft ins.prop line)

Stock: 24 ft  $3\frac{1}{4}$ " copper tubing same curb stop box

Insp. F Bento

=====

Street reconstruction May 13, 1997

REnewed from main to curb stop

Stock: 24ft  $3\frac{1}{4}$ " copper tubing 1- $3\frac{1}{4}$ " curb stopsame caldwell stop box 1- $3\frac{1}{4}$ " x  $5\frac{1}{8}$ " Fig 413  
=====

DATE

BEF.

AFT.

REMARKS

2-9-98 9506-01804

Clear Elec.

5/13/97: tap reamed

[illegible]

## CHARGE OUTS

[illegible]