

APPLICATION No.: 19197 5/8"

TAP CLEARED

LOCATION: 234-236 Bates St.

OWNER: E. Persin

MEASURES:

5/8"

E from	Arlington	118.7 ft.
N from S line	Bates	7.0 ft.
E from W line	House	8.3 ft.

June 13, 1958 Repaired leak at tap.  
1 lb. wiping solder.

2/5/79: Renewed 6" outside curbstop to 3.6 ft. inside  
curb stop. 4 ft.-3/4" copper; 3/4" curb stop; 2-5/8" x  
3/4" lead-cop. adapt. XS; Caldwell stop box;

10-19-01 Renewed from main to property line. Stock: 14ft.-3/4"  
Copper tubing, 1-3/4" Curb Stop, 1-Caldwell Stop Box, 1-5/8"x3/4"  
lead to cop. adapt. XS, 1- 5/8"x3/4" Fig. 413

DATE

BEF.

AFT.

REMARKS

10-4-01

8:00

2001-400-2122

10-19-01 Tap reamed

## METER HISTORY

## CHARGE OUTS

[illegible]