

APPLICATION No.: 1923

LOCATION: 172 - 174 Washington St

OWNER:

31-313

MEASURES:	W X	Sears St	119.7 ft
	N X	S Washington St	6.4 ft
	W X	W House	3.7 ft

1" Copper Service 9/24/2018

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 80

Distance from main to curb stop (ft) 7

Distance from curb stop to meter (ft) 20.2

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.2

Total length of new pipe installed (ft) 20.2

Curb stop replaced: no size 3/4

Corporation replaced: no size 3/4

Ball valve replaced: Yes size 1"

Remarks: 1-3/4 union installed 1.0 ft out curb
stop

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

2/11/76	Ream
---------	------

[illegible]