

APPLICATION No.: 19321

LOCATION: 114-116 Deane S.S., W. of Acushnet Ave.

OWNER: Michl Parent

MEASURES:

5/8" Ser. increased to 3/4" from curb Stop into  
Bldg. 7-12-65 3/4" Meter

WW from	Acushnet Ave.	101.3
N from S line	Deane	9.2
E from W line	Bldg.	8.0

July 12, 1965 Renewed from  $\frac{3}{8}$  ft. outside curb stop to  
meter inside building 12 ft. of  $\frac{3}{4}$ " copper tubing  
 $\frac{3}{4}$ " cop. to cop. stop, fig. 415 lb. wiping solder

5/1/79: Franklin Const. renewed serv. from the main to the curb stop. 11 ft.-3/4" copper; 5/8" x 3/4" Fig. 413; 3/4" curb stop; Caldwell stop box;

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]