

APPLICATION No.: 19409TAP CLEARED 8248-1222LOCATION: 363-65 Shaw N.S., E. of BrookOWNER: Mrs. Almpza E. Macedo

MEASURES: 5/8" 3/4" Copper
E from Brook 98.0 ft.
S from N line Shaw 7.0 ft.
W from E line House 13.2 ft.

February 2, 1971 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line.

10 ft. of 3/4" copper tubing 1 3/4" Hays curb stop
2 wipe joints

DEC 7 1982 -- Renewed from main to a point 2 ft. from main. 2.0 ft. - 3/4" copper; 5/8" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XS;

9/16/10 Leak before shut off 9/20/10 letter sent

12/7/10 - City crew renewed service from main to meter inside cellar

32 ft - 3/4" copper tubing; 1 Caldwell stop box; 1 - 5/8" x 3/4" Fig 413; Tap cleaned; 2 - 3/4" meter couplings; 1 - 3/4" shut-off inside cellar; 2 - 3/4" 90 degree bends

Foreman: Foreman: Dana Farland

DATE

BEF.

AFT.

REMARKS

DEC 7

1982

Reamed

[illegible]

CHARGE OUTS

[illegible]