

APPLICATION No.:

OWNER:

31-313

1" COPPER SERVICE

W from County St 233.0'

N from S Line Grinnell St 6.6'

W from E Line House 8.5'

9-11-2018: Lead service line replacement program

Phase 1- Contractor P. Gioioso & Sons

TYPE:CU, Diameter 1", Water Pressure 90

Distance from main to curb stop 6.8'

Distance curb stop to meter 18.5'

Distance from curb face to curb stop 1.4'

Depth of service 4.3'

Total length of new pipe installed 25.3'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished: YES Size 1"

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]