

APPLICATION No.: 19452

TAP CLEARED

LOCATION: 1048 Phillips Rd. S.S. W. of Acushnet Ave.

DATE

BEF.

AFT.

REMARKS

OWNER: Eugene Roy

MEASURES: 3/4"

W from

1st hydt. W. of Acush, Ave. 149.6 ft.

N from S line

Phillips Rd. 11.6 ft.

W from E line

House 10.2 ft.

6/30/95: tap reamed

June 30, 1995:

Todesca Corp renewed service from the main to prop line

Cont. supplied all stock & will maintain trench

20 ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 5/8 Fig 413

Insp. D Monty

Additional measures: W to E line house 10.0 ft
E to W line house 14.6 ft

July 13, 1995: Contractor pulled tap from main

Repaired by contractor

Stock used: 1-3/4" tap REdhead 1-3/4x3/4 Fig 413

1- 3/4 x 3/4 cop-cop cplg.

Poor Pressure 12-8-95

[illegible]

1048 Phillips Rd. APPLICATION No:

APPLICATION No.:

19452

OWNER:

31-313

MEASURES:

W x 1st Hydrant w x Acushent Ave 149.6'

N x S Line Phillips Rd	11.6
------------------------	------

W x E Line House 10'

E x W Line House 14.6

N x N Line House 32'

Main to Property Line 18'

Pipe Inside Property 30'

8/3/2022 renewed c/s to Meter Farland Co

Percy R inspected

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]