

19460

APPLICATION No.:

LOCATION: 157-159 Hadley St (SS) E x Acushnet Ave

TAP CLEARED ✓

OWNER:

31-313

MEASURES: 3/4" Lead 06-01-1923

W from W line Kearsage St	307.0
E from Hydrant # 5-0640	255.5
S from N line Hadley St	83.0
W from E line House	11.0
E from W line House	17.0
S from S line House	23.0
Main to Property Line	32.0
Pipe inside P roperty	17.0

10/6/08 - New measures listed above - see card for
old measures. Inspected by Percy Reynolds

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 19460

TAP CLEARED

LOCATION: 157-159 Hadley N.S., E. Of Acushnet Ave

OWNER: Philip Munroe

MEASURES:

5/8"

E from	Acushnet Ave.	295.0
S from N line	Hadley	8.3
W from E line	House	10.0

DATE

BEF.

AFT.

REMARKS

5-29-07

2:30

2007-210-7601

9-27-07

2007-390-9321

9-27-07

Tap Reamed

1-24-08

8.00

2008-030 3210

2-21-08

Tap reamed

Sept. 19, 1951 1 ft. inside curb stop.
 1 ft. outside curb stop 2 ft. of 3/4" Copper tubing
 3/4" Cop. to cop. stop, Fig. 415

MAY 18 1983 --Renewed from 13 ft. south of stop box to
 17 ft. south of box. 4.0 ft. - 3/4" copper; 3/4" curb stop;
 (15 ft. S of box); 2- 5/8" x 3/4" lead-cop. adapt. XS;

9/27/07 - Renewed from main to curb stop - tap leak
 Stock: 12 ft - 3/4" cop tubing; 1 - 3/4" curb stop; Tap reamed.
 Broke sewer service - Repaired 9/28/07 J. Velez

2/21/08 - City renewed service from main to property line
 32 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell stop
 box; 1 - 5/8" x 3/4" lead to cop adapt. xxs; 1 - 5/8" x 3/4"
 Fig. 413. Tap reamed. Foreman: Frank Bento

[illegible]

CHARGE OUTS

[illegible]