

APPLICATION No.: 19486

TAP CLEARED

LOCATION: 298-300 Harwich S.S., W. of Felton

DATE

BEF.

AFT.

REMARKS

OWNER: H. Payles

MEASURES:

3/4" Copper
5/8"

W from	Felton	107.2
N from S line	Harwich	8.4
E from W line	House	4.2

Nov. 16, 1960 Renewed from 1 ft. outside curb stop to 1 ft. inside curb stop
2 ft. of 3/4" copper tubing
3/4" cop. to cop. stop, fig. 415 Red Hed
2 lb.s wiping solder

September 6, 2002: Renewed from new 8" main to property line; 16 ft. - 3/4" copper tubing; 1-3/4" curb stop; 1-caldwell stop box; 1-5/8 x 3/4 lead to cop. adapt.XXS; 1-3/4" corporation tap

12/8/10 - City crew renewed service from 1/2' outside curb stop to inside cellar & had to repair 4" storm drain & 6" sewer service

22 ft 3/4" copper tubing; 1 Caldwell stop box; 2 - 3/4" meter couplings; 1 - 3/4" shut-off in cellar; 2 - 4" Fernco clay to PVC; 2 - 6" Fernco clay to PVC
1 - 20 ft length of 4" SDR 35 PVC & 1 - 20 ft length of 6" SDR 35 PVC. Foreman: Dana Farland

11/29/10 8:45

2010-4802223

[illegible]