

236-32

APPLICATION No.: 19549

TAP CLEARED ✓

LOCATION: S.E. Cor. Myrtle &amp; Sawyer

OWNER: \_\_\_\_\_

MEASURES:

3/4"

E from

Myrtle

42.0 ft.

N from S line

Sawyer

8.2 ft.

W from E line

House

19.5 ft. 34c

6/2/03 Renewed from the new 8" main to a point 2 ft. Stock: 2 ft.  
3/4" copper tubing; 3/4" corp tap; 3/4" x 3/4" cop to cop cplg.,  
comp. Inspected by: D Grenon  
-----

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 19549

## TAP CLEARED

LOCATION: S.E. Cor. 236-38 Myrtle &amp; Sawyer

DATE BEF. AFT. REMARKS

OWNER: Sacred Heart Credit Union

9-27-99 Tap reamed

MEASURES: 3/4"

E from	Myrtle	42.0 ft.
N from S line	Sawyer	8.2 ft.
W from E line	House	19.5 ft.

Oct. 19, 1959 Renewed from  $\frac{1}{2}$  ft. outside curb stop to  
2 ft. inside curb stop.

2 $\frac{1}{2}$  ft. - 3/4" Copper tubing 3/4" cop to cop stop  
2# wiping solder

- - -

9-27-99 DW White renewed from main to property line.  
Stock: 18 ft. - 3/4" Copper tubing, 1 - 3/4" Curb stop,  
1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt.  
XXS, 1 - 5/8"x3/4" Fig. 413. DW White to maintain cut.

10-7-99 Renewed from curb stop to ins. cellar. (6 ft. ins.  
prop. line). Stock: 12 ft. - 3/4" Copper tubing.

10/7/99 199941068-4

[illegible]

## CHARGE OUTS

[illegible]