

APPLICATION No.: 19573

TAP CLEARED ✓

LOCATION: 127A - 129A Clara St.

OWNER: Ovilla E. Pariseau Et Ux

MEASURES: 5/8" H. lead July 13, 1923

E from Cleveland St. 25.4 ft.

S from N line Clara St. 8.4 ft.

E from W line House 21.4 ft.

Feb. 20, 1973 Renewed from 1/2 ft. outside curb stop to property line.

8 1/2 ft. - 3/4" Copper tubing 3/4" Hays curb stop  
2 wipe joints - - -10/18/05 Renewed from main to curb stop. Stock: 25 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 3/4" x 3/4" cop-cop cplg., comp; 5/8" cplg Fig. 413 Monty  
Note: Hit top of surface drain in street and repaired. Stock: 1 bucket water plug; 3 ft. 12" PVC pipe  
-----08.30.2019 - Lead Service Line Replacement Program-Phase 1  
Contractor P. Gioioso and Sons

Type: CU, Diameter (in) 1, Water Pressure 100

Distance from main to curb stop (ft) N/A

Distance curb stop to meter (ft) 26

Distance from curb face to curb stop (ft) 2

Depth of Service (ft) 4

DATE

BEF.

AFT.

REMARKS

6/23/18

982600370

2-19-99

19990803554

10/17/05

10 AM 2005-

10/18/05

Tap Reamed

[illegible]

## CHARGE OUTS

[illegible]

19573

APPLICATION No.:

LOCATION: 127 - 129 Clara St

OWNER:

31-313

**MEASURES:**

Total length of new pipe installed (ft) 26

Curb stop Replaced : No

Corporation Replaced : No

Ball Valve Furnished : Yes, Size 1"

TAP CLEARED

DATE \_\_\_\_\_

BEF.


AFT.

REMARKS

[illegible]

[illegible][illegible]

### CHARGE OUTS



Remarks:

[illegible]