

APPLICATION No.: 19589 3/4" Killed

TAP CLEARED

LOCATION: 4292 Acushnet Ave.

OWNER: R. J. Yaouette

MEASURES: 3/4"

N from
W from E line
N from S line

Tobey 26.2 ft.
Acushnet Ave. 6.4 ft.
House 1.2 ft.

Feb. 13, 1968 Renewed from 1/2 ft. outside curb stop,
to a point 4 1/2 ft. inside curb stop.

5 ft. - 3/4" copper tubing; 1-3/4" Mueller curb stop;
2 wipe joint; 1-Buffalo Stop Box

Sept. 24, 1976 Renewed from the main to 1 ft. from
main.

1 ft. - 3/4" Copper tubing 3/4" x 1" Fig. 413
1 - 5/8" x 3/4" lead to copper adaptor XXS

March 7, 1995: Poor pressure dug & reamed tap
Used same adaptors and same Fig. 413

=====

11/29/01 Shut off at curb stop only. Replaced by N.S. # 32304-1"

11/28/05 Repaired 10" storm drain Stock: 30 ft. 10" PVC; 2 -
1" clay-PVC Fernco.

10/4/2008 Killed Service at Tap on 36" Main; abandoned
in place foreman: Danny Perry

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

9/24/76

Reamed

3/7/95

9510-01179

CLEAR ELECT.

METER HISTORY

CHARGE OUTS

[illegible]

CHARGE OUTS