

APPLICATION No.: 19627

TAP CLEARED

LOCATION: 475 Orchard Bolton E.S. S. Of Røvet

OWNER: Ashley Park

MEASURES: 3/4"

08/07/1923

S from

Rivet

3.2 ft.

E from W line

Orchard

9.4 ft.

June 26, 1956 1 wiped joint in meter box - rewiped outside joint inside meter box.

April 25, 1997: NO PRESSURE PIPE BENT IN PIT WORK DONE IN PIT
 Stock: 4.5ft 3/4" copper tubing 1-3/4" ball valve w/waste
 1-3/4 x 3/4 cop-cop cplg. 1-3/4x3/4 Fig 413 1-3/4 backflow
 hose connection M Rose III

6-22-99 Spicket renewed from meter pitt to utility cage.
 Stock: 10 ft.- 3/4" Copper tubing, 1 - 3/4" Curb stop.

6-24-99 Repairs made inside meter pit only. Stock:
 2 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
 1 - 1" x 3/4" lead to cop. adapt. XXS.
 Stock installed in this order. 1 - 1" x 3/4" lead to cop
 adapt. XXS, 1 - 6" x 3/4" Copper tubing, 1 - 3/4" Curb Stop
 1 - 6" cop. tubing w 3/4" adapt. soda, 2 - 3/4: meter
 coupling, 1 - 1" x 3/4" cop. tubing, w 3/4" adapter soda.

2/19/09 - City crew renewed service from main to a point 2 ft
 2 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop cplg. comp;
 1 - 3/4" corp tap; 1 - 10" x 3/4" service saddle.
 Foreman: Frank Bento

DATE

BEF.

AFT.

REMARKS

4/29/97

9716-0664

6-22-99 Tap reamed

2/18/09 8:00

2009-0801550

2-19-09

Tap reamed

[illegible]

CHARGE OUTS

[illegible]

19627

475 Orchard St

Ashley Park

OWNER:

31-313

MEASURES:

2/19/09 - City crew renewed service from main to property line
due to leak at curbstop

13 ft - 3/4" copper tubing; 1 Caldwell stop box; 1 - 5/8" x 3/4"
lead to cop adapt; tap reamed. Foreman: Jesse Velez

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]