

APPLICATION No.: 19703

TAP CLEARED

LOCATION: 43 Jouvette St

DATE _____

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: Aug. 31, 1923

W X County St	492.7 ft
---------------	----------

S X N Line Jouvette St 8.4 ft

E X W Line House 1.0 ft

1" Copper Service

07/31/2019 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 26

Distance from curb stop to meter (ft) N/A

Distance from curb face to curb stop (ft) 3


Depth of service (ft) 4.5

Total length of new pipe installed (ft) 26

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no size 3/4"

[illegible][illegible]

APPLICATION No.: 19703

TAP CLEARED 8636-3089

LOCATION: 43 Jouvette St.

OWNER: Jerome Barao

MEASURES: 5/8" H lead Aug. 31, 1923

W from County St. 492.7 ft.

S from N line Jouvette St. 8.4 ft.

E from W line house 1.0 ft.

SEP 3 - 1980

Renewed 6" outside of curb stop to property line.

2-5/8" x 3/4" lead to copper XXS

3/4" curb stop

9 ft. 3/4" copper curb box

9/11/86: Renewed from prop line to ins. cellar. (10.0 ft.
ins prop line) Stock: 10,0 ft. 3/4" copper tubing1 - 3/4 x 3/4 cop to cop cplg. comp.
=====

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]