

APPLICATION No.: 19724

TAP CLEARED

LOCATION: 4306 Acushnet Ave. E.S. S x May

OWNER: Peter Landry

COPPER

DATE

BEF.

AFT.

REMARKS

5/22/75

Reamed

MEASURES: <sup>3/4"</sup> S from May St. 25.7 ft.  
 W from E line Acushnet Ave. 5.6 ft.  
 N from S line House 2.2 ft.

May 22, 1975 Renewed from the main to a point 3 ft.  
 inside property line. Owner supplied copper  
 52 ft. - 3/4" Copper tubing ( 3 ft. inside)  
 3/4" Curb Stop Caldwell Stop Box  
 1 wipe joint 3/4" x 3/4" Fig. 413

- - -

9/17/08 - North End Pressure Project - Tied service into new 12"  
 water main . No stock used. Foreman: Danny Perry

-----

12/14/17: Lead service line replacement program

Contractor: P. Gioioso &amp; sons.

Distance cur ~~B~~ stop to meter 4.0'Distance from cur ~~B~~ face to cur ~~B~~ stop 4.3'

Depth of service 4.5'

Total length of new pipe installed 54'

Cur ~~B~~ stop replaced: NO size 3/4"

Corporation replaced NO size 3/4"

Ball valve furnished YES Size 1"

comments: roots from tree grew into existing water shut off box

existing 1" gas service steel on top of water service


one 1" x 3/4" adapt. used 6" behind existing curb stop.

Distance from main to curb stop (#): N/A

## METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS



ACUSHNET AVE



APPLICATION No.: 197243(3/4")

TAP CLEARED

LOCATION: 4306 Acushnet Ave.

OWNER: Peter Landry

MEASURES:

3/4" COPPER

S from May 25.7 ft.

W from E line Acushnet Ave. 5.6 ft.

N from S line house 2.2 ft.

July 23, 1968 Renewed from  $\frac{1}{2}$  ft. outside curb stop  
to property line.

8 $\frac{1}{2}$  ft. - 3/4" copper tubing; 1 - 3/4" curb stop Mueller;  
2 wipe joints.

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]