

APPLICATION No.: 19726 3/4" L lead

TAP CLEARED

LOCATION: 3728 Acushnet Ave.

OWNER: John Bradley

MEASURES: 3/4"

L lead

Sept. 18, 1923

S from 7th hyd. s. of Bradley Rd. 239.3 ft.

W from E line Acushnet Ave. 7.6 ft.

N from S line House 6.6 ft.

April 24, 1958 Renewed from a point $\frac{1}{2}$ ft. outside curb
stop to a point 3 ft. inside curb stop.

$3\frac{1}{2}$ ft. - $3\frac{1}{4}$ " copper tubing; 1 - $3\frac{1}{4}$ " copper stop;
2 lbs. wiping solder.

12/6/06 Renewed from main to property line. Stock: 50 ft. $3\frac{3}{4}$ "
copper tubing; $3\frac{3}{4}$ " curb stop; Caldwell stop box; $3\frac{3}{4}$ " x $3\frac{3}{4}$ "
lead-cop adapt. XS; $3\frac{3}{4}$ " x $3\frac{3}{4}$ " Fig. 413 Tap reamed Bento

4/23/07 Renewed from main to a point 3 ft. Stock: 3 ft. $3\frac{3}{4}$ " copper
tubing; $3\frac{3}{4}$ " x $3\frac{3}{4}$ " cop-cop cplg., comp; $3\frac{3}{4}$ " corp tap Bento

3/26/2018: Lead service line replacement program, phase 1
Contractor P. gioioso & Sons

Diameter 1": Type: CU: Water Pressure 58;

Distance from main to cur l stop 31'

Distance cur l stop to meter 38.7'

Distance from cur l face to cur l stop 4.8'

depth of service 4.8'

total length of new pipe installed 38.7'

DATE

BEF.

AFT.

REMARKS

11/21/06

10:30

2006-460-5989

12/6/06

Tap reamed

METER HISTORY

CHARGE OUTS

[illegible]