

APPLICATION No.: 19761

TAP CLEARED

LOCATION: 123 Plymouth St.OWNER: Saul Epstein

DATE

BEF.

AFT.

REMARKS

1-31-72

Reamed

MEASURES:

5/8"

L lead

Nov.30,1923

W from

Rockdale Ave.

171.2 ft.

S from N line

Plymouth St.

8.3 ft.

W from E line

house

2.8 ft.

March 11, 1964 Renewed from $\frac{1}{2}$ ft. outside curb stop to 5 ft.
inside curb stop.

5 $\frac{1}{2}$ ft. 3/4" copper tubing 1 3/4" cop. to cop. stop
2 lbs. wipingsolder

January 31, 1972 Leak at the tap.

3 ft. 3/4" dopper tubing 1 3/4" x 3/4" fig. 413
1 wiped joint

4-24-01 Silva Const. renewed from newly installed 8"
main to 1.0 S x prop. line. Stock: 31 ft. - 3/4" Copper
tubing, 1 - 3/4" curb stop, 1 - Caldwell Stop Box,
1 - 5/8" x 3/4" lead to cop. adapt.XS, 1 - 3/4" Corporation
tap. Silva Const. to maintain cut.

[illegible]

CHARGE OUTS

[illegible]