APPLICATION No.: 19762 5/8#	TAP CLEARED			
LOCATION: 181-183 Church St.	DATE	BEF.	AFT.	REMARKS
OWNER: E. Lassey	9/26/6	0		reamed
MEASURES: 5/0#				
5/8" S from Belleville Rd. 146.5 ft.				
E from W line Church 6.0 0.0 ft.				
S from N line House 4.8 ft. E from Porch 9.2 ft.				
1-3/4"x3/4" cop. to I.F. coupleing, fig. 413 1-3/4" lead to copper coupling - Ford				
1-C.L. stop box & lead returned to shop				
Sept. 26, 1960 Renewed from main to property line.  18 ft 3/4" Copper tubing 3/4" Copper stop				
see above for remainder of stock.				
5/8/18: Lead service line replacement program phase 1 Type: CU, Diameter 1, Water Pressure CO				
Type: CU, Diameter 1, Water Pressure (2)				
Distance curb stop to meter 15.5				
Type: CU, Diameter 1, Water Pressure 68 Distance from main to curb stop N/A Distance from curb face to curb stop 2.0' Total length of new pipe install				
Total length of new pipe installed 18.5'				
Curb stop replaced No: Size N/A Corporation replaced No: Size N/A Ball Valve furnished YES; Size N/A				
		4		

