

1993

TAP CLEARED

LOCATION: 77 Willis Cor. Summer

OWNER: E. Sweeney

MEASURES:

 $3/4''$

N from Willis 37.5 ft.

W from E Summer 6.2 ft.

S from N house 22.5 ft.

May 9, 1977: Repair from curb stop to inside cellar wall. 16 ft.-
3/4" copper (8 ft. ins.); 3/4" curb stop; 5/8" x 3/4" lead to copper
adapt. XXS; Caldwell stop box;

1/12/88: Renewed from main to a point 15.0 ft. from main.

Stock: 15 ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt.xxs

1 - 3/4x5/8 Fig.413

=====

[illegible]