

APPLICATION No.: 19937

TAP CLEARED

LOCATION: 523 - 525 Nash Road

| DATE | BEF. | AFT. | REMARKS |
|------|------|------|---------|
|------|------|------|---------|

OWNER:

5/23/60 Ream

31-313

MEASURES: E X Mt Pleasant St

281.9 ft

3/29/93

S X N Line Nash Rd

6.8 ft

7/17/2000 Tap

E X W Line House

3.7 ft

1" Copper Service

05/07/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 60

Distance from main to curb stop (ft) 33.0

Distance curb stop to meter (ft) 42.5

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 3.7

Total length of new pipe installed (ft) 42.5

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1'-3/4" union installed 1.0' from curb stop

METER HISTORY

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST | | | REMARKS |
|------|---------|------|------|--------|---------|------|--|--|---------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

CHARGE OUTS

