

APPLICATION No.: 19957

TAP CLEARED ✓

LOCATION: S.E. Cor. 42 So. Sixth & Madison

OWNER: Tifereth Israel Congregation

MEASURES: 2"

Darling gate I box

S from Madison 27.2 ft.

W from E line Sixth 6.6 ft.

S from N line Bldg. 12.0 ft.

September 29, 1948 Replaced 2" Service & 1" lead goosenecks
with 2" copper tubing type "K" & 1" copper goosenecks.
From tap to inside the cellar.

4/13/05 Tapped into 20" main with 3 - 1" taps connecting into a
2" connection. Service was reduced to 1" in cellar. Repaired
leak by discontinuing 2 - 1" taps. renewed from main to a
point 7 ft. Hit by Gas Co.

STOCK: 7 ft. 1" copper tubing; 1" x 1" Fig. 413; 2" x 1" solder
cplg.; Tap Reamed.

DATE

BEF.

AFT.

REMARKS

4/13/05 9:30 am 2005-160-6265

[illegible]

CHARGE OUTS

[illegible]

42 South Sixth.

APPLICATION No.: 19957

TAP CLEARED



LOCATION: S.E. Cor. So Sixth & Madison

OWNER:

MEASURES: 2" Darling gate I. box

S from

W from E line

S from N line

Madison

Sixth

Bldg.

27.2 ft.

6.6 ft.

12.0 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

42 So. Sixth St. 4/12/05



← 678

water
main