

117 PLEASANT ST

APPLICATION No.: 1996

TAP CLEARED 8570-1786

LOCATION: 115-117 Pleasant

OWNER: C Xavier

3 FAMILY

MEASURES:

5/8"

N from Grinnell 213.1

E from W line Pleasant 6.6

N from S line house 2.3

3/7/85: Renewed from 1/2' outside curb stop to ins. cellar (9.0 Ft.) ins prop line) Stock: 16.0 ft. 3/4" copper tubing 1 3/4" curb stop 1 Caldwell stop box 1 3/4x5/8 lead to cop adapt. comp. xxs

=====

Sept 5, 1997: Renewed from main to a point 1.4ft

Stock: 1.4ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xs

1- 1/2 x 3/4 Fig 413

=====

March 24, 2003: Renewed from main to a point 8 ft; 8 ft-3/4" copper tubing; 1-3/4x3/4 cop. to cop. cplg. comp.; 1-5/8x3/4 Fig. 413

10/09/13 City crew renewed service from 1/2' outside curb stop to inside cellar
Stock: 17ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 - Caldwell stop box;
1 - 3/4" corp tap; 1 - 6"x3/4" service saddle J.Medeiros

DATE BEF. AFT. REMARKS

9/5/97

973606058.

tap reamed 9/5/97

3/24/03

2003-130-1039

10/9/13

2013-4105750

[illegible]

CHARGE OUTS

[illegible]