

APPLICATION No.: 20023

TAP CLEARED ✓

LOCATION: Water W.S. of Gifford

OWNER: 1011 SO. WATER - 16300 TOBACCO

MEASURES: 6" FIRE SUPPLY

Darling gate I box

S from S	Gifford	140.4 ft.
E from W	Water	7.7 ft.
S from N	Bldg.	52.9 ft.

Nov. 9, 1983 J.F. KENNEDY HWY. PROJ. Dow Co. tied in
fire supply to new 8" Water St. main. Installed from the
main to a point 1.5 ft. east of old 6" gate.

Installed in following order:

8" x 8" x 6" Tee, Mech.

15" pc. of 6" ductile pipe

SEE SKETCH ON S.L. CARD

6" Mueller gate valve, mech.

3 ft. - 6" ductile pipe

1 - 6" 1/8 Bend, mech. (facing up & north)

2 ft. - 6" ductile pipe

1 - 6" 1/8 Bend, mech.

2 ft. - 6" ductile pipe

1 - 6" Smith Blair #441 cplg. to exist. pipe

All truss blocked & rodged

All stock supplied by Forte Bros.

Measures of new 6" Mu. gate valve:

S x S line Division St. 244.0 ft.

E x W line So. Water St. 16.0 ft.

[illegible]

CHARGE OUTS

[illegible]