

20070

TAP CLEARED

LOCATION: 20-22 Fielding E.S. ,S. of Wood

OWNER: Joseph Gabeil

MEASURES: $5/8''$ $3/4''$ Lead

4/11/1925

S from	Wood	143.0
W from Eline	Fielding	9.0
S from N line	House	5.1

June 6, 1962 "Renewed from 1' outside curbstop to 1' inside curb
stop: rewiped joint at tap 2 ft. of 3/4" copper tubing
3/4" cop. to cop. stop, fig. 415/3 lbs of wiping solder

JUN 22 1981 Renewed from main to 2 ft. outside of main.
2 ft. - 3/4" copper; 5/8" x 3/4" Fig. 413; 5/8" x 3/4"
lead-cop. adapt. XS

7/30/91: Renewed from main to prop line
Stock: 30ft. 3/4" copper tubing 1-3/4" curb stop
1- Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs
same Fig.413;

9/10/10 - City crew renewed water service from 1/2 ft outside curb stop to a point 2 ft inside property line 10 ft -3/4" copper tubing; 1 -5/8" x 3/4" lead-cop adapt. xs. Foreman: Danny Perry

12/21/10 - Felix was called in by Quittacas regarding curb stop leak on private property - owner to go to office in the A.M. to sign Notification of Charges to hire City to make repairs

[illegible]

CHARGE OUTS

[illegible]

20070

APPLICATION No.:

LOCATION: 20 - 22 Fielding St (ES) S x Wood St

OWNER:

31-313

MEASURES:

12/22/10 - City crew renewed water service from curb stop to meter

24 ft - 3/4" copper tubing; Foreman: Danny Perry

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

[illegible]

CHARGE OUTS

[illegible]