

APPLICATION No.: 20074

TAP CLEARED



LOCATION: 128-130 LOCUST ST S.S. E X SHAWMUT AVE

OWNER: FRANK C HOLMES

MEASURES: 3/4"

E from SHAWMUT AVE 113.0ft  
N from S line LOCUST ST 5.2 ft  
E from W line HOUSE 0.6 ft

April 22,1996:

REnewed from main to a point 4ft

Stock: 4ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp

4ft outside of tap 1-3/4" corporation tap 1-8x3/4 serv.saddle

=====

DATE

BEF.

AFT.

REMARKS

[illegible]

### CHARGE OUTS



APPLICATION No.: 20074

TAP CLEARED

LOCATION: 128-130 Locust S. S., E. of Shawmut Ave.

DATE

BEF.

AFT.

REMARKS

OWNER: Frank C. Holmes

MEASURES: 3/4"

E from

Shawmut Ave.

113.0 ft.

N from S line

Locust

5.2 ft.

E from W line

house

0.6 ft.

Dec. 17, 1968 Renewed from  $\frac{1}{2}$  ft. outside curb stop to the property line.

$4\frac{1}{2}$  ft. - 3/4" Copper tubing 3/4" Curb stop  
Stop Box 2 wiped joints  
- - -

March 25, 1975 Renewed from the property line to inside cellar.

18 ft. - 3/4" Copper tubing ( inside)

3/4" sweat cplg. ( at prop. line)

MAY 21 1982 --Tilcon renewed from the main to the curb stop. 9.3 ft. - 3/4" copper; 3/4" x 1" Fig. 413;  
- - -

unplanned street caving in  
Block like a washboard.

Trench went down  
very little 7/27/90



[illegible]

## CHARGE OUTS

[illegible]