

APPLICATION No.: 20101

TAP CLEARED

LOCATION: 108 South Sixth St

DATE

BEF.

AFT.

REMARKS

OWNER:

12/23/92

31-313

MEASURES: S X Wing St 181.0 ft  
W X E Line South Sixth St 6.0 ft  
N X S Line House 8.0 ft

1" Copper Service

08/09/2019 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 19.6

Distance curbstop to meter (ft) 19.8

Distance from curb face to curb stop (Ft) 1.7

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 39.4

Curb stop replaced: Yes size 1"

Corporation replaced: yes size 1"

Ball valve replaced: Yes size 1"

[illegible]