

APPLICATION No.: 20132 5/8"

TAP CLEARED 880F 1796

LOCATION: 401-403 Cedar Grove

OWNER: Ernesto Gentili

MEASURES: 5/8"

E from	Reynolds	104.0 ft.
S from N line	Cedar Grove	9.0 ft.
W from E line	House	6.4 ft.

Aug. 13, 1965 Renewed service from main to 1 ft. from main.

1 ft. - 3/4" copper tubing; 1 - 5/8" reused corp. cplg;
1# wiping solder; Tap reamed;

1/7/88: Renewed from 1/2' outside curb stop to a point 4 ft.

Stock: 5 ft. 3/4" copper tubing 1 - 3/4" curb stop

1 - Caldwell stop box 2 - 3/4x5/8 lead to cop adapt. xs.

NOTE: BIG ROCK OVER THE LEAD GOING NORTH OF PROP LINE.

ALSO DRAIN IS ON THE RIGHT INSIDE OF THE CURB STOP--WEST SIDE

+++++

9/28/93: Renewed from 2ft inside curb stop to ins.cellar

14ft ins.prop line Stock: 18ft 3/4" copper tubing

1-3/4x3/4 cop-cop cplg.comp.

CHAP 90

=====

9/13/93: CH 90 PROJECT Medeiros & son Cont. renewed from new 8" main to curb stop all stock supplied by Cont.

24.3 ft 3/4" copper tubing same 3/4" curb stop same Caldwell stop box 1-3/4" corporation tap Mueller Insp. M Rose III

=====

DATE

BEF.

AFT.

REMARKS

8/13/65

Reamed

CHAPTER 90 PROJECT

3-15-94

94/1101239

8-2-04

8:15

2004-320-0492

4' just clb drain job - no work done @ this prop.

METER HISTORY

CHARGE OUTS

[illegible]