

SERVICE

Application No. 20139

St. &amp; No.

R 461 1/2  
Sawyer N.S. E. of Myrtle

Size Pipe

5/8"

Kind Pipe

L lead

Laid

July 16, 1924

E	from		Myrtle	St.	244.8 ft.
S	from	N	line Sawyer	St.	9.1 ft.
W	from	E	line house	St.	2.0 ft.

City

33 ft. Earth

32 ft. Pipe

Taker

Labor ft. Earth etc.

127 1/2 ft. Pipe

Rep'g street

1	85
33	15
24	53
31	00
90	53

Nov 15, 1953, ser. leak, renewed 1 ft. from main to a point 1 ft. from main. renewed 1 ft. from outside of curb stop to inside meter box 3 ft. from curb stop. 5 ft.  $3/4$ " cop. tubing type K. 2 wiped joints, tap reamed.

9-7-1955, ser. leak, renewed from the meter (meter box in sidewalk) to a point  $1/2$  ft. toward property line using  $1/2$  ft.  $3/4$ " cop. tubing type K. soft. 2 wiped joints. 11/8/76 Renewed from the main to point 3 ft. in front of main. 3 ft.  $3/4$ " copper;  $5/8$ " x  $3/4$ " lead to copper adaptor XXS;

12/28/79 renewed 1' outside curb stop to curb stop; 1'  $3/4$ " copper; 1'  $5/8$ " x  $3/4$ " lead cop adapt.