

APPLICATION No.: 20148

TAP CLEARED

LOCATION: Union S.S., W. of Sixth

OWNER:

MEASURES:

4"

Darling gate, 1 FIRE

SUPPLY

W from

Sixth

84.8 ft.

N from S line

Union

29.7 ft.

E from W line

bldg.

27.3 ft.

January 19, 1964 Repaired broken spindle on 4" tapping gate
(Darling).

1 4" Darling Spindle 1 gasket 1 set of bolts

~~00000~~

[illegible]

CHARGE OUTS

[illegible]