

LOCATION: 56 Clark S.S. W. of County St.

OWNER: Antonio Rodriques

MEASURES: 5/8"

W from

County

121.7 ft.

N from S line

Clark

6.9 ft.

E from W line

Bldg.

60.8 ft.

Mar. 13, 1961 Renewed from  $\frac{1}{2}$  ft. outside curb stop to 3 ft.  
inside curb stop  $3\frac{1}{2}$ ' of  $\frac{3}{4}$ " copper tubing

$\frac{3}{4}$ " cop. to cop. stop, fig. 415

2 lbs. wiping solder

---

April 13, 1976 Renewed from the main to the prop.  
line

17 ft. -  $\frac{3}{4}$ " Copper tubing  $\frac{3}{4}$ " Curb Stop

Stop Box  $\frac{3}{4}$ " x  $\frac{3}{4}$ " Fig. 413

$\frac{3}{4}$ " x  $\frac{3}{4}$ " lead to copper adaptor

---

DATE

BEF.

AFT.

REMARKS

4/13/76

Reamed

## METER HISTORY

## CHARGE OUTS

[illegible]