

APPLICATION No.: 20212

TAP CLEARED 84050028

LOCATION: 96 Jenny Lind E.S., N. of Hillman

OWNER: Harley Smith

MEASURES: 3/4"

N from

Hillman

203.1 ft.

W from E line

Jenny Lind

5.7 ft.

N from S line

House

0.9 ft.

Feb. 2, 1984 - Renewed from 1/2 ft. outside curb stop  
to property line.

6 ft. - 3/4" copper tubing

1 - 3/4" curb stop 1 stop box

2 - 3/4" x 5/8" lead to copper adaptors XXS

-----

✓ 5/24/89: Renewed from curb stop to ins. cellar(18 ft. ins.  
prop line) Stock: 24 ft. 3/4" copper tubing.

✓ Renewed from main to curb stop. Stock: 1 - 3/4" Copper  
tubing, 1 - 3/4" Curb Stop(same), 1 - Caldwell Stop Box  
(same), 1 - 3/4" x 3/4" Fig. 413. DW White to maintain cut.

6/11/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to a point 5.5 ft

5.5 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer

Inspected by Tim Ives, CDM

-----

DATE

BEF.

AFT.

REMARKS

8921-2893

✓ 10-20-99 Tap reamed



[illegible]

## CHARGE OUTS

[illegible]