

211109 Service killed

APPLICATION No.: 2028

TAP CLEARED

LOCATION: 64 Hazard Street

OWNER: Wm & Geo Dumas

MEASURES: ~~5/8"~~ 3/4"

E from County 185.6 ft.

N from S line Hazard 7.4 ft.

W from E line body of house 1.1 ft.

Sept. 3, 1975 Renewed from 6" outside curb stop to
inside cellar.

16 ft. - 3/4" Copper tubing (8 ft. inside)

3/4" Curb stop Buffalo Stop Box

5/8" x 3/4" lead to copper adaptor XS

— — —

March 4, 1976 Renewed from the main to the property line.
 1 1/4 ft. - 3 1/4" Copper tubing 2 1/4" x 5'

14 ft. - 3/4" Copper tubing 3/4" Corporation

3/4" Curb Stop

5/8" x 3/4" lead connector

1000 K. S. CHOI

2/11/2009 Service killed at tap, removed curb stop
Bldg. demolished by Fire

[illegible]

CHARGE OUTS

[illegible]