

APPLICATION No.: 20284

TAP CLEARED ✓

LOCATION: 79 Scott St. N.S, E of Crapo

OWNER: M Ferreira

MEASURES: 5/8"
E from crapo 337.7 ft
S from N line Scott 8.3 ft
E from W line House 2.8 ft

9/6/90: Renewed from curb stop in the middle of the
street to curb stop on the sidewalk

Stock: 15 ft. 3/4" copper tubing 1 - 3/4" curb stop
=====

6/29/94: Renewed from curb stop to ins.cellar (13ft ins.prop line)
Stock: 21ft 3/4" copper tubing same curb stop same Caldwell
stop box
=====

DATE

BEF.

AFT.

REMARKS

6/29/94 942603320

4

[illegible]

CHARGE OUTS

APPLICATION No.: 20284

TAP CLEARED 8311 0265
T846793

LOCATION: 79 Scott N.S. E. of Crapo

9/6 = 9036-2947

OWNER: M. Ferreira

MEASURES:

5/8"

E from	Crapo	337.7 ft.
S from N line	Scott	8.3 ft.
E from W line	House	2.8 ft.

DATE

BEF.

AFT.

REMARKS

9-3-69

Reamed

11/19/84 tap reamed

8634-1821

8/21/85: Renewed from main to a point

9 ft. Stock: 9ft. 3/4" copper

tubing 1 - 3/4" curb stop

1 - 3/4 x 5/8 lead to cop adapt. xxs

=====

Inst. a 3/4" curb stop buried at

a point 8 1/2 ft. from main.

Ledge 8 ft. from main. Lead goes

around ledge 2 ft. to curb stop

in sidewalk.

SIDEWALK

LEDGE

CURB STOP BURIED

MAIN

September 3, 1969 Renewed from the main to a point 4 ft. from the main.

4 ft. of 3/4" copper tubing 1 3/4" x 3/4" fig. 413
1 wipe joint

April 20, 1976 Renewed from the main to 6 ft. from the main.

6 ft. - 3/4" Copper tubing 5/8" x 3/4" lead to
copper adapt. XXS

March 17, 1977 Renewed from 6" outside curb stop to a point 6 ft. inside curb stop.

6 1/2 ft. - 3/4" Copper tubing 3/4" curb stop
Caldwell Stop Box 2 - 5/8" x 3/4" lead to cop.
adaptor XXS

Cannot renew to line due to ledge. Found broken drain & repaired it.

Nov 19, 1984: Renewed from main to a point 7.0 ft.

Stock: 7.0 ft. 3/4" copper tubing 1 3/4 x 5/8 lead to
cop adapt. XXS 1 5/8 Fig 413

[illegible]

CHARGE OUTS

[illegible]