

APPLICATION No.: 20379

TAP CLEARED ✓

LOCATION: 954 Thorndike S.S., E. of Acushnet Ave. ✓

OWNER: Geo. Wilbur

DATE

BEF.

AFT.

REMARKS

4/5/07

Tap reamed

MEASURES: 3/4"

E from E line	Acush. Ave.	487.0 ft.
E from E line	House	2.6 ft.
N from S line	Thorndike	8.0 ft.

-----  
 April 16 to 20, 1954 Renewed from tap to a point 2 ft. from tap.  
 2 ft. of 3/4" copper tubing 1 3/4" corp. fig. 438 R.H.  
 -----

4/5/07 Renewed from main to property line. Stock: 14 ft. 3/4" cop  
 tubing; 3/4" curb stop; Caldwell stop box; 3/4" (oversized) lead-cop  
 adapt. XXS; 3/4" x 3/4" cop=cop cplg. comp; Tap reamed D Monty

1" Copper Service - - - - -

3/9/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure N/A

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (Ft) 37

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 37

Curb stop replaced: NO

Corporation replaced: No

Ball valve replaced: Yes size 1"

Remark: new 1" copper length includes 3 ft interior

connection to water main

[illegible]

\_\_\_\_\_

