

APPLICATION No.: 20441

TAP CLEARED

LOCATION: 49 Alden St.

OWNER: Diana P. Freitas Et Ux

MEASURES: 5/8" L lead Dec.2,1924

W from Ridge St. 114.0 ft.

S from N line Alden St. 8.4 ft.

E from W line house 3.4 ft.

Feb 11, 1963 Renewed from 1/2 ft. outside curb stop to 2 1/2 ft. inside curb stop

2 3 ft. of 3/4" copper tubing type K, soft

1 3/4" cop. to cop. stop, fig. 415

2 lbs. wiping solder

1 sidewalk cut. 5' x 2' dirt

#125 compressor: 1 hr.

Abraham, Fernandes, Sousa

Sept. 18, 1995: Renewed from main to prop line

Stock: 30ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 5/8 Fig 413

2/28/12 - City crew renewed water service from main to curb stop damaged by NStar Gas

28 ft - 3/4" copper tubing; 1 -3/4" curb stop;

1 caldwell stop box; 1 - 5/8" x 3/4" Fig 413; tap

cleaned. Foreman: Frank Bento

DATE

BEF.

AFT.

REMARKS

9/18

953800387

9/18/95: tap reamed OK. ELEC.

METER HISTORY

CHARGE OUTS

[illegible]