

LOCATION: 201-203 Bates St.

OWNER: D. Roy

DATE BEF. AFT. REMARKS

12/23/88: TAP REAMED

MEASURES: 5/8"

W from	Acushnet Ave.	259.8 ft.
S from N line	Bates	7.2 ft.
E from W line	House	15.0 ft.

Nov. 22, 1976 Renewed from $\frac{1}{2}$ ft. outside curb stop to the property line.

6 $\frac{1}{2}$ ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " Curb Stop
Caldwell Stop Box 2 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead conn.

June 18, 1979: Renewed from 1.4 ft. - outside curb stop.
 $\frac{1}{2}$ ft. - $\frac{3}{4}$ " copper; $\frac{5}{8}$ " x $\frac{3}{4}$ " lead-cop. adapt. XS;
 $\frac{3}{4}$ " curb stop; Caldwell stop box;

12/23/88: Renewed from main to 1.6 ft. outside curb stop
Stock: 18 ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{3}{4}$ cop to cop cplg
comp. 1.5 ft. outside curb stop 1- $\frac{3}{4}$ /x $\frac{5}{8}$ Fig.413

=====

METER HISTORY

CHARGE OUTS

[illegible]