

APPLICATION No.: 20498

TAP CLEARED ✓

LOCATION: 24-6 Luke St.

OWNER: Casimiro Dias Lameiras, Et Ux

MEASURES: 3/4"

L lead

Feb. 20, 1925

2/18/04

Tap reamed

E from

Ridge St.

129.0 ft.

N from S line

Luke St.

9.3 ft.

E from W line

house

3.8 ft.

Jan. 6, 1964 Renewed from 1/2 ft. outside curb stop to

1 1/2 ft. inside curb stop

2 ft. 3/4" copper tubing

1 3/4" cop. to copl stop, fig 415

2 lbs. wiping solder

1 sidewalk cut: 6' x 4' dirt

Letendre

Jakusik

2/18/04 Renewed from main to property line. Stock:

16 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop

box; 5/8" x 3/4" lead-cop adapt. XXS; 3/4" x 3/4" Fig.

413 Tap reamed

2/18/04 Repaired 4" drain & repaired 6" SS. Stock:

4" plastic cplg; 2 - 4" clay-plastic; 14 ft. 4" PVC;

14 ft. 6" PVC; 6" clay-plastic

TURN CARD OVER FOR ADDITIONAL WORK DONE TO SERVICE

[illegible]

APPLICATION No.: 20498

TAP CLEARED

LOCATION: 24-26 Luke St

DATE _____

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

12/7/09 - City crew reset curb stop & repaired section of storm drain service that got damaged while working on curb stop

1 - Caldwell stop box; 2 ft - 4" PVC pipe; 2 - 4" straight Fernco's. Foreman: dennis Monty

8/17/10 - City crew reset curb stop
No materials used. Foreman: Dan Perry

[illegible]