

APPLICATION No.: 2051

TAP CLEARED

LOCATION: 104 State Cor. Pearl

OWNER: F.A. Delano

MEASURES: 5/8"

S from	Pearl	38.4 ft.
W from E line	State	6.5 ft.
S from S line	House	5.2 ft.

8/22/79: Franklin renewed service from the main to the meter. 32 ft. - 3/4" copper (6' inside); 3/4" curb stop; stop box; 3/4" corp. tap

Sept 28, 1995: Cont. #1 Water main repl
S & B Cont. renewed service from the newly installed 8" main to a point 3ft Contractor supplied stock:
3ft - 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp
1- 3/4" corporation tap
Main is 26ft lin W x E line S&B Cont. to maintain trench
Insp. Manny Borges

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

Note: Installed a 4" repair sleeve over old tap which leaked. Service had to be retapped.

Measures for 4" Sleeve Repair-2

S x S line Pearl St. 48 ft.

E x W line State St. 14 ft.

[illegible]

CHARGE OUTS

[illegible]