

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

5/17/89: TAP REAMED

3/29/06 Tap Reamed

8920-3197

S from 3d hyd N. of Nye's Lane 62.0 ft.

W from E line Acush. Ave. 6.8"ft.

S from N line house 12.0 ft.

Dec. 7, 1974 Renewed from 6" outside curb stop to property line.

7 ft. - 3/4" Copper tubing 3/4" Curb Stop

Caldwell Stop Box	1 wipe joint (at prop line)
-------------------	------------------------------

5/8" x 3/4" lead to copper adaptor XXS

5/17/89: Renewed from main to a point 3 ft.

Stock: 3ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt.xxs

1 - $3/4 \times 3/4$ Fig. 413

3/29/06 Renewed from main to curb stop

Stock: 35' of 3/4" copper tubing, 3/4" curb stop, stop box,

5/8 x 3/4 Fig. 413, tap reamed

Aug. 22, 2007 - N.E. Pressure Project. tied service into new 12" Main.

Y

CHARGE OUTS

[illegible]