

APPLICATION No.: 20584

TAP CLEARED

LOCATION: 63-65 Query N.S., E. of Aushnet Ave

OWNER: N.B. 5¢ Savings Bank

MEASURES:

5/8"

E from Acushnet Ave

376.2

S from N line Query^a

8.6

W from E line house

7.0

Complained of poor pressure in cellar only
8/29/90 will call back after checking Iwro.

7/25/06 Renewed from main to property line. Stock: 35 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead-cop adapt. XXS; 5/8" x 3/4" Fig. 413 Tap reamed

NOTE: Repaired 4" storm drain

[illegible]