

LOCATION: 222-24 Aquidneck St.

OWNER: William Wallace

MEASURES: 3/4" ~~Copper H head~~ Apr. 22, 1925  
W from Brock Ave. 336.0 ft.

N from S line Aquidneck St. 9.0 ft.

E from W line house 16.3 ft.

Aug. 4, 1958 Renewed from curb stop to inside cellar.  
25 ft. - 3/4" copper tubing; 1 lb. wiping solder.

Jan. 12, 1981: Renewed from 1.0 ft. outside of curbstop  
to 1.0 ft. inside curbstop.

2.0 ft. - 3/4" copper

1-3/4" curb stop 1-Caldwell stop box

1-3/4" x 3/4" Cop.-cop. comp.cplg.

1-5/8" x 3/4" lead-cop. adapt. XXS

12/11/2020: DPI, Ronald Aguiar, repaired the water  
service from the main to the curb stop 1-cast iron curb  
stop boxes

1 3/4" box copper tubing -1 5/8" corp adapter  
1 3/4" curb stop valve

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]