

APPLICATION No. 20614

## TAP CLEARED

LOCATION: 19 Ohio N.S., W. Acushnet Ave.

OWNER: \_\_\_\_\_

MEASURES: 5/8

W from	Acushnet Ave.	185.4 ft.
S from N line	Ohio	9.3 ft.
W from E line	House	4.4 ft.

June 26, 1995:

Renewed from main to curb stop Stock: 25ft 3/4" copper tubing  
1- 3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 Fig 413  
NOTE: 7ft curb stop to prop line 15ft ins.prop line to cellar  
plumber supplied this copper John Golda Acushnet Trenching  
did digging ins.prop line TAP IS 5 FT E X CURB STOP

=====

9/19/05 Renewed from curb stop to a point 8 ft. outside curb stop.  
Stock: 8 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box;  
3/4" x 3/4" cop-cop cplg., comp.

-----

12/13/10 - City crew renewed water service from main  
to a point 3.5 ft from curb stop  
15 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop-cop  
cplg. comp. Foreman: D. Farland

-----

DATE

BEF.

AFT.

REMARKS

952600290

6/26/95: tap reamed

12/13/10 8:15

2010-5100436

[illegible]

## CHARGE OUTS

[illegible]