

20680

APPLICATION No.:

LOCATION: 158-160 Hadley St (SS) E x Acushnet Ave

OWNER:

31-313

MEASURES: 3/4" Copper

05-25-1925

W from W line Kearsage St	309.5
---------------------------	-------

E from Hydrant # 5-0640 253.0

N from S' line Hadley St 10.5

W from E line House 30.5

E from W line House	2.0
---------------------	-----

House to Box	23.0
--------------	------

Main to Property Line	18.0
-----------------------	------

Pipe inside Property	14.0
----------------------	------

10/6/08

New measures listed above. See card for old measures

Inspected by Percy

.....

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 20680

TAP CLEARED 8957-2108 ✓

LOCATION: 158-160 Hadly S.S.E. of Acushnet Ave.

OWNER: Alphoner Lizotte

MEASURES:

5/8"

E from	Acushnet Ave.	332.0
N from S line	Hadley	8.6
E from W line	House	1.3

Dec. 7, 1989 renewed from 1 ft. outside curb stop to a point
1 ft. ins.

2 ft. - 3/4" copper tubing 1 - 3/4" curb stop 1 stop box

1 - 5/8" x 3/4" lead to cop adapt XXS

Dec. 22, 1989 Sewer broken on Dec. 7, 1989 while repairing water
leak, had to be dug out by Water Dept. and after much debate was
repaired by Kenny Rebello & Pete Sanzano - DPW Const. Foreman & DPW Assist. Commissioner.

2/7/08 - City renewed service from main to property line

18 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell stop

box; 1 - 5/8" x 3/4" lead to cop adapt. xxs; 1 - 5/8" x 3/4"

Fig. 413. Tap Reamed Foreman: Frank Bento

Fig. 413

DATE

BEF.

AFT.

REMARKS

T903-807

5-29-07

2:30

2007-210-7606

1-24-08 8:00

2008-030 3212

[illegible]

CHARGE OUTS

[illegible]